



**Dhr. Maurice Pijnen**  
**DESSO BV**  
**Postbus 169**  
**NL-5140 AD WAALWIJK**  
**NEDERLAND**

Your notice of

Your reference

our reference

date

PW/3865

2008-04-22

## Certification Report Nr. 08/3865

Modification of certification report Nr. 07/368 dd. 2007-01-15

### 1. Description of the flooring:

Product group:                Needed carpet tiles - FR  
                                          Bitumen backed  
                                          70% polyamide – 30% polyester needed without pile

Total mass:                     4100 g/m<sup>2</sup>

Effective pile thickness:    2.2 mm

### 2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
B <sub>fl</sub>	E <sub>fl</sub>	heat flux ≥ 8.0 kW/m <sup>2</sup>

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose laid on a non-combustible substrate

**B<sub>fl</sub> - s1**

This report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel. The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

*Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment*

#### CENTEXBEL GENT


Technologiepark 7  
BE-9052 Zwijnaarde (Gent)  
Tel. +32 9 220 41 51  
Fax +32 9 220 49 55  
e-mail gent@centexbel.be

#### CENTEXBEL BRUSSELS

Montoyerstraat 24-B2  
BE-1000 Brussels  
Tel. +32 2 287 08 30  
Fax +32 2 230 68 15  
e-mail brussel@centexbel.be

#### CENTEXBEL VERVIERS

Avenue du Parc 38  
BE-4650 Herve (Chaineux)  
Tel. +32 87 32 24 30  
Fax +32 87 34 05 18  
e-mail chaineux@centexbel.be



**Addressee**  
DESSO BV

**our ref.**  
PW/3865

**date**  
2008-04-22

**page number**  
2

Related commercial names to this product group are:  
FORTO

The obtained classification is based on the next test reports:  
Centexbel: 43235/B of 2004-12-17  
Centexbel: 60461/D of 2008-01-22

Certificate valid until 2013-01-22

Petra Wittevrongel  
certification coordinator