



eurofins

Certificate

On 31st January 2007 Eurofins Environment A/S received a sample of a floor covering with the name

Eternal Forbo Flooring Systems

The floor covering sample has been selected by Forbo-Novilon B.V. as being representative for the floor coverings of the type Eternal.

The emissions were tested according to the AgBB-scheme and guidelines of the DIBt (AgBB - Committee for Health-related Evaluation of Building Products, DIBt – German Institute for Building Technology). Sampling, testing and evaluation were performed according to ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see test report no. 758358.

Evaluation of the test result according to AgBB/DIBt guidelines:

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
- The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
- The sum of SVOC after 28 day was below the limit of 0.1 mg/m³.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
- The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.

The tested product complies with the requirements of DIBt (June 2004) in combination with the NIK values from AgBB (September 2005) for use in the indoor environment.

23rd May 2007

Thomas Neuhaus
Environmental Engineer

Inge Bondgaard
M.Sc. (Chemistry)

Eurofins Environment A/S
Smedeskovvej 38
DK-8464 Galten /
Denmark

Tel +45 70 22 42 66
Fax +45 70 22 42 55